

**Veeder-Root
(originally listed as Marley Pump Co.)**

Red Jacket FX1, FX2, FX1V, FX2V

AUTOMATIC MECHANICAL LINE LEAK DETECTOR

- Certification:** Leak rate of 3.0 gph with $P_D = 100\%$ and $P_{FA} = 0\%$.
- Leak Threshold:** 2.0 gph. A pipeline system should not be declared tight if the test result indicates a loss that equals or exceeds this threshold.
- Applicability:** Gasoline, diesel, aviation fuel.
Other liquids may be tested after consultation with the manufacturer.
- Specification:** System tests pressurized fiberglass and steel pipelines.
Tests are conducted at 8-12 psi.
- Pipeline Capacity:** Maximum of 316 gallons for FX1 and FX1V.
Maximum of 362 gallons for FX2 and FX2V.
- Waiting Time:** None between delivery and testing.
None between dispensing and testing.
Stabilization time up to 45 minutes may be required after dispensing when temperature extremes are present.
- Test Period:** Response time is less than 5 minutes.
- System Features:** Permanent installation on pipeline.
Automatic testing of pipeline.
Preset threshold.
Single test to determine if pipeline is leaking.
Restricted flow to dispenser if leak is declared.
- Calibration:** System must be checked annually and, if necessary, calibrated in accordance with manufacturer's instructions.

Veeder-Root
125 Powder Forest Dr.
Simsbury, CT 06070-2003
Tel: (860) 651-2700

Evaluator: Ken Wilcox Associates
Tel: (816) 443-2494
Dates of Evaluation: 03/14/94, 06/01/94